

TADCO

Engineering & Environmental Services, LLC

**PO BOX 711
NORTH BERGEN, NJ 07047**

**TEL: 201-222-5322
FAX: 201-222-2442**

March 4, 2005

54 Terrace Avenue
Jersey City, NJ 07307

**Reference: EZY-3 Underground Storage Tank Testing
54 Terrace Avenue
Jersey City, NJ
#05-0300-01**

Dear Ms. Platt:

Following please find the test results of the EZY3 Locator Plus vacuum acoustic precision test performed on the 550-gallon #2 fuel oil underground storage tank and associated piping located at the above property. All testing confirms to U.S.E.P.A and N.J.D.E.P. tank testing criteria and the results are as follows:

<u>Date</u>	<u>Tank</u>	<u>Pass/Fail</u>
03-04-2005	550 gal #2	PASS

The test indicates that no vacuum is entering the subject tank. No leaks are detected.

The test indicates that the body of the tank and piping are tight at the time of testing. In light of these results, we recommend that you obtain a tank insurance policy against future leaks.

Enclosed please find the tank testing field information sheet.

If you have any questions or require additional information, please do not hesitate to contact me.

Best regards,



Safwat Tadrous, P.E.
NJ DEP License #USO1172